

## PHARMACOPOEIAL DISCUSSION GROUP

## CORRECTION

CODE: G-01

NAME: ANALYTICAL SIEVING

(Correction of the sign-off document Rev. 1 signed on May 8, 2007)

Item to be corrected:

- 1) The sieve diameters listed in harmonized document were changed from "200 mm" to "200 mm or 203 mm (8-inch)" and from "76 mm" to "75 mm or 76 mm (3-inch)" respectively.
- 2) Some editorial changes were made to the "TEST SIEVES" section of the text.
- 3) USP adds the following note to the section of Test Specimen as USP local text: "The 8-inch (203 mm) frame diameter sieve is equivalent to the 200 mm frame diameter sieve. The 3-inch (76 mm) frame diameter sieve is equivalent to the 75 mm frame diameter sieve."

## European Pharmacopoeia

Signature

*P. Doerr*

Name

*Petra Doerr*

Date

*28/10/2021*

## Japanese Pharmacopoeia

Signature

*Y. Goda  
for Y. Yoshida*

Name

*Yukihiko Goda*

Date

*15 Nov, 2021*

## United States Pharmacopoeia

Signature

*K.T. Moore*

Name

*KEVIN MOORE*

Date

*9 - NOV - 2021*

1  
2  
3  
4  
5

**PARTICLE SIZE  
DISTRIBUTION ESTIMATION  
BY ANALYTICAL SIEVING**

6 Sieving is one of the oldest methods of classifying powders and granules by particle size  
7 distribution. When using a woven sieve cloth, the sieving will essentially sort the particles by their  
8 intermediate size dimension (i.e., breadth or width). Mechanical sieving is most suitable where  
9 the majority of the particles are larger than about 75  $\mu\text{m}$ . For smaller particles, the light weight provides  
10 insufficient force during sieving to overcome the surface forces of cohesion and adhesion that cause  
11 the particles to stick to each other and to the sieve, and thus cause particles that would be expected to  
12 pass through the sieve to be retained. For such materials other means of agitation such as air-jet sieving  
13 or sonic sifting may be more appropriate. Nevertheless, sieving can sometimes be used for some  
14 powders or granules having median particle sizes smaller than 75  $\mu\text{m}$  where the method can be  
15 validated. In pharmaceutical terms, sieving is usually the method of choice for classification of  
16 the coarser grades of single powders or granules. It is a particularly attractive method in that powders  
17 and granules are classified only on the basis of particle size, and in most cases the analysis can be  
18 carried out in the dry state.

19 Among the limitations of the sieving method are the need for an appreciable amount of sample  
20 (normally at least 25 g, depending on the density of the powder or granule, and the diameter of test  
21 sieves) and difficulty in sieving oily or other cohesive powders or granules that tend to clog the sieve  
22 openings. The method is essentially a two-dimensional estimate of size because passage through  
23 the sieve aperture is frequently more dependent on maximum width and thickness than on length.

24 This method is intended for estimation of the total particle size distribution of a single material.  
25 It is not intended for determination of the proportion of particles passing or retained on one or two  
26 sieves.

27 Estimate the particle size distribution as described under *Dry Sieving Method*, unless otherwise  
28 specified in the individual monograph. Where difficulty is experienced in reaching the endpoint (i.e.,  
29 material does not readily pass through the sieves) or when it is necessary to use the finer end of  
30 the sieving range (below 75  $\mu\text{m}$ ), serious consideration should be given to the use of an alternative  
31 particle-sizing method.

32 Sieving should be carried out under conditions that do not cause the test sample to gain or lose  
33 moisture. The relative humidity of the environment in which the sieving is carried out should be  
34 controlled to prevent moisture uptake or loss by the sample. In the absence of evidence to the contrary,  
35 analytical test sieving is normally carried at ambient humidity. Any special conditions that apply to a  
36 particular material should be detailed in the individual monograph.

37 **Principles of Analytical Sieving**—Analytical test sieves are constructed from a woven-wire  
38 mesh, which is of simple weave that is assumed to give nearly square apertures and is sealed into the  
39 base of an open cylindrical container. The basic analytical method involves stacking the sieves on top  
40 of one another in ascending degrees of coarseness, and then placing the test powder on the top sieve.

41 The nest of sieves is subjected to a standardized period of agitation, and then the weight of  
42 material retained on each sieve is accurately determined. The test gives the weight percentage of  
43 powder in each sieve size range.

44 This sieving process for estimating the particle size distribution of a single pharmaceutical  
45 powder is generally intended for use where at least 80% of the particles are larger than 75  $\mu\text{m}$ . The size  
46 parameter involved in determining particle size distribution by analytical sieving is the length of  
47 the side of the minimum square aperture through which the particle will pass.

48

49 **TEST SIEVES**

50

51 Test sieves suitable for pharmacopeial tests conform to the current edition of International  
 52 Organisation for Standardization (ISO) ISO 3310 - 1 specification; Test sieves – Technical  
 53 requirements and testing – Part 1: Test sieves of metal wire cloth. Unless otherwise specified in  
 54 the monograph, use those ISO sieves listed in Table 1 as recommended in the particular region.  
 55

56

57

**Table 1. Sizes of Standard Sieve Series in Range of Interest**

Principal sizes	ISO Nominal Aperture		US Sieve No.	Recommended USP Sieves (microns)	European Sieve No.	Japan Sieve No.
	Supplementary sizes					
	R 20/3	R 20				
11.20 mm	11.20 mm	11.20 mm			11200	
	10.00 mm	9.50 mm				
	9.00 mm					
8.00 mm	8.00 mm	8.00 mm				
	7.10 mm	6.70 mm				
	6.30 mm					
5.60 mm	5.60 mm	5.60 mm			5600	3.5
	5.00 mm	4.75 mm				4
	4.50 mm					
4.00 mm	4.00 mm	4.00 mm	5	4000	4000	4.7
	3.55 mm	3.35 mm	6			5.5
	3.15 mm					
2.80 mm	2.80 mm	2.80 mm	7	2800	2800	6.5
	2.50 mm	2.36 mm	8			7.5
	2.24 mm					
2.00 mm	2.00 mm	2.00 mm	10	2000	2000	8.6
	1.80 mm	1.70 mm	12			10
	1.60 mm					
1.40 mm	1.40 mm	1.40 mm	14	1400	1400	12
	1.25 mm	1.18 mm	16			14
	1.12 mm					
1.00 mm	1.00 mm	1.00 mm	18	1000	1000	16
	900 µm	850 µm	20			18
	800 µm					
710 µm	710 µm	710 µm	25	710	710	22
	630 µm	600 µm	30			26
	560 µm					
500 µm	500 µm	500 µm	35	500	500	30
	450 µm	425 µm	40			36
	400 µm					
355 µm	355 µm	355 µm	45	355	355	42
	315 µm	300 µm	50			50
	280 µm					
250 µm	250 µm	250 µm	60	250	250	60
	224 µm	212 µm	70			70
	200 µm					
180 µm	180 µm	180 µm	80	180	180	83
	160 µm	150 µm	100			100
	140 µm					
125 µm	125 µm	125 µm	120	125	125	119
	112 µm	106 µm	140			140

90 $\mu\text{m}$	100 $\mu\text{m}$ 90 $\mu\text{m}$ 80 $\mu\text{m}$	90 $\mu\text{m}$	170	90	90	166
		75 $\mu\text{m}$	200			200
63 $\mu\text{m}$	71 $\mu\text{m}$ 63 $\mu\text{m}$ 56 $\mu\text{m}$	63 $\mu\text{m}$	230	63	63	235
		53 $\mu\text{m}$	270			282
45 $\mu\text{m}$	50 $\mu\text{m}$ 45 $\mu\text{m}$ 40 $\mu\text{m}$	45 $\mu\text{m}$	325	45	45	330
		38 $\mu\text{m}$			38	391

58

59

60

61

62

63

64

Sieves are selected to cover the entire range of particle sizes present in the test specimen. A nest of sieves having a  $\sqrt{2}$  progression of the area of the sieve openings is recommended. The nest of sieves is assembled with the coarsest screen at the top and the finest at the bottom. Use micrometers or millimeters in denoting test sieve openings. [NOTE—Sieve numbers are provided in the table for conversion purposes only.] Test sieves are made from stainless steel or, less preferably, from brass or other suitable non-reactive wire.

65

66

67

68

69

70

71

Calibration and recalibration of test sieves is in accordance with the most current edition of ISO 3310 - 1. Sieves should be carefully examined for gross distortions and fractures, especially at their screen frame joints, before use. Sieves may be calibrated optically to estimate the average opening size, and opening variability, of the sieve mesh. Alternatively, for the evaluation of the effective opening of test sieves in the size range of 212 to 850  $\mu\text{m}$ , Standard Glass Spheres are available. Unless otherwise specified in the individual monograph, perform the sieve analysis at controlled room temperature and at ambient relative humidity.

72

73

74

**Cleaning Test Sieves**—Ideally, test sieves should be cleaned using only an air jet or a liquid stream. If some apertures remain blocked by test particles, careful gentle brushing may be used as a last resort.

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

**Test Specimen**—If the test specimen weight is not given in the monograph for a particular material, use a test specimen having a weight between 25 and 100 g, depending on the bulk density of the material, and test sieves having a diameter of 200 mm or 203 mm (8-inch). For sieves of 75 mm or 76 mm (3-inch) diameter the amount of material that can be accommodated is approximately  $1/7^{\text{th}}$  of which can be accommodated on a 200 mm or 203 mm sieve. Determine the most appropriate weight for a given material by test sieving accurately weighed specimens of different weights, such as 25, 50, and 100 g, for the same time period on a mechanical shaker. [NOTE—If the test results are similar for the 25-g and 50-g specimens, but the 100-g specimen shows a lower percentage through the finest sieve, the 100-g specimen size is too large.] Where only a specimen of 10 to 25 g is available, smaller diameter test sieves conforming to the same mesh specifications may be substituted, but the endpoint must be re-determined. The use of test samples having a smaller mass (e.g. down to 5 g) may be needed. For materials with low apparent particle density, or for materials mainly comprising particles with a highly iso-diametrical shape, specimen weights below 5 g for a 200 mm or 203 mm sieve may be necessary to avoid excessive blocking of the sieve. During validation of a particular sieve analysis method, it is expected that the problem of sieve blocking will have been addressed.

90

91

92

93

94

95

96

97

98

99

100

If the test material is prone to picking up or losing significant amounts of water with varying humidity, the test must be carried out in an appropriately controlled environment. Similarly, if the test material is known to develop an electrostatic charge, careful observation must be made to ensure that such charging is not influencing the analysis. An antistatic agent, such as colloidal silicon dioxide and/or aluminum oxide, may be added at a 0.5 percent (m/m) level to minimize this effect. If both of the above effects cannot be eliminated, an alternative particle-sizing technique must be selected.

**Agitation Methods**—Several different sieve and powder agitation devices are commercially available, all of which may be used to perform sieve analyses. However, the different methods of agitation may give different results for sieve analyses and endpoint determinations because of the different types and magnitude of the forces acting on the individual particles under test. Methods using mechanical agitation or electromagnetic agitation, and that can induce either a vertical oscillation

101 or a horizontal circular motion, or tapping or a combination of both tapping and horizontal circular  
102 motion are available. Entrainment of the particles in an air stream may also be used. The results must  
103 indicate which agitation method was used and the agitation parameters used (if they can be varied),  
104 since changes in the agitation conditions will give different results for the sieve analysis and endpoint  
105 determinations, and may be sufficiently different to give a failing result under some circumstances.  
106

107 **Endpoint Determination**—The test sieving analysis is complete when the weight on any of  
108 the test sieves does not change by more than 5% or 0.1 g (10% in the case of 75 mm or 76 mm sieves)  
109 of the previous weight on that sieve. If less than 5% of the total specimen weight is present on a given  
110 sieve, the endpoint for that sieve is increased to a weight change of not more than 20% of the previous  
111 weight on that sieve.

112 If more than 50% of the total specimen weight is found on any one sieve, unless this is indicated  
113 in the monograph, the test should be repeated, but with the addition to the sieve nest of a more coarse  
114 sieve intermediate between that carrying the excessive weight and the next coarsest sieve in the original  
115 nest, i.e., addition of the ISO series sieve omitted from the nest of sieves.  
116

## 117 SIEVING METHODS

### 118 **Mechanical agitation**

119 **Dry Sieving Method**—Tare each test sieve to the nearest 0.1 g. Place an accurately weighed  
120 quantity of test specimen on the top (coarsest) sieve, and replace the lid. Agitate the nest of sieves for  
121 5 minutes. Then carefully remove each from the nest without loss of material. Reweigh each sieve,  
122 and determine the weight of material on each sieve. Determine the weight of material in the collecting  
123 pan in a similar manner. Reassemble the nest of sieves, and agitate for 5 minutes. Remove and weigh  
124 each sieve as previously described. Repeat these steps until the endpoint criteria are met (see *Endpoint*  
125 *Determination* under *Test Sieves*). Upon completion of the analysis, reconcile the weights of material.  
126 Total losses must not exceed 5% of the weight of the original test specimen.  
127

128 Repeat the analysis with a fresh specimen, but using a single sieving time equal to that of the  
129 combined times used above. Confirm that this sieving time conforms to the requirements for endpoint  
130 determination. When this endpoint has been validated for a specific material, then a single fixed time  
131 of sieving may be used for future analyses, providing the particle size distribution falls within normal  
132 variation.

133 If there is evidence that the particles retained on any sieve are aggregates rather than single  
134 particles, the use of mechanical dry sieving is unlikely to give good reproducibility, a different particle  
135 size analysis method should be used.  
136

### 137 **Air Entrainment Methods**

138 **Air Jet and Sonic Sifter Sieving** —Different types of commercial equipment that use a  
139 moving air current are available for sieving. A system that uses a single sieve at a time is referred to  
140 as *air jet* sieving. It uses the same general sieving methodology as that described under the *Dry Sieving*  
141 *Method*, but with a standardized air jet replacing the normal agitation mechanism. It requires  
142 sequential analyses on individual sieves starting with the finest sieve to obtain a particle size  
143 distribution. Air jet sieving often includes the use of finer test sieves than used in ordinary dry sieving.  
144 This technique is more suitable where only oversize or undersize fractions are needed.

145 In the *sonic sifting* method, a nest of sieves is used, and the test specimen is carried in a vertically  
146 oscillating column of air that lifts the specimen and then carries it back against the mesh openings at a  
147 given number of pulses per minute. It may be necessary to lower the sample amount to 5 g, when  
148 sonic sifting is employed.

149 The air jet sieving and sonic sieving methods may be useful for powders or granules when  
150 mechanical sieving techniques are incapable of giving a meaningful analysis.

151           These methods are highly dependent upon proper dispersion of the powder in the air current.  
152 This requirement may be hard to achieve if the method is used at the lower end of the sieving range  
153 (i.e., below 75  $\mu\text{m}$ ), when the particles tend to be more cohesive, and especially if there is any tendency  
154 for the material to develop an electrostatic charge. For the above reasons endpoint determination is  
155 particularly critical, and it is very important to confirm that the oversize material comprises single  
156 particles and is not composed of aggregates.  
157

#### 158 **INTERPRETATION**

159

160           The raw data must include the weight of test specimen, the total sieving time, and the precise  
161 sieving methodology and the set values for any variable parameters, in addition to the weights retained  
162 on the individual sieves and in the pan. It may be convenient to convert the raw data into a cumulative  
163 weight distribution, and if it is desired to express the distribution in terms of a cumulative weight  
164 undersize, the range of sieves used should include a sieve through which all the material passes. If  
165 there is evidence on any of the test sieves that the material remaining on it is composed of aggregates  
166 formed during the sieving process, the analysis is invalid.  
167  
168